

APPENDIX-XI

BUILDING SAFETY CERTIFICATE

No. 2801/A.C.1/~~1~~

Dated 27/12/2024

Certified that the existing building Powayan Public Senior Secondary School at Khutar, Shahjahanpur comprised of Ground Floor & First Floor (upper floors) owned/occupied by Powayan Public Senior Secondary School have complied with the Building safety requirements in accordance with National Building code Rules. And verified by the officers concerned of Surendra Kumar (A.E.) & Animesh Srivastava (J.E.) on 27-12-2024 in the presence of Manager Powayan Public Senior Secondary School, Khutar Road Powayan, Shahjahanpur and that the building/premises is fit for occupancy upto classes 12th Class with effect from 27-12-2024 For a period of 26-12-2025 years in accordance with rule and subject to compliance of the specific conditions as appended.

- 1- 6.00 mt. open area must be required around the building (N.B. Code Part-3 clause 8.3.1(a))
- 2- Provision of Earth quick Resistance drawing (as per Zone-III) must be required.
- 3- Stair width of building is not less than 1.50 mt. and rise 150 mm. and Read 300 mm must be required (NB Code Part-3 Clause 12.18)
- 4- Height of Parapet wall of building is not less than 1.00 mt. and not above than 1.20 mt (N.B. Code Part-3 Clause-12.11)

Issued on Friday 27-12-2024 at 04:00 P.M. By

❖ Strike our whichever is not applicable.


Assistant Engineer

Signature with Seal : P.D. P.W.D.


Name Surendra Kumar

Designation : Assistant Engineer

Name & Address of Department/Office : Provincial Division, PWD, Shahjahanpur

(Assistant Engineer & above officer of concerned Govt. Department Only)

Note : This certificate should be signed/ issued by Assistant Engineer & above officer of concerned Govt. Department only.

❖ The filled up certificate should be either in Hindi or English. If it is issued in vernacular language. translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.